

## Evaluation of the performance of three ASTM E 2058 and NFPA 287 fire propagation apparatuses

Guy Marlair, Archibald Tewarson

► **To cite this version:**

Guy Marlair, Archibald Tewarson. Evaluation of the performance of three ASTM E 2058 and NFPA 287 fire propagation apparatuses. 9. International Fire Science

Engineering Conference, Sep 2001, Edimbourg, United Kingdom. pp.1255-1260, 2001. <ineris-00976143>

**HAL Id: ineris-00976143**

**<https://hal-ineris.archives-ouvertes.fr/ineris-00976143>**

Submitted on 9 Apr 2014

**HAL** is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

# EVALUATION OF THE PERFORMANCE OF THREE ASTM E 2058 AND NFPA 287 FIRE PROPAGATION APPARATUSES

**Guy Marlair<sup>(a)</sup> & Archibald Tewarson<sup>(b)</sup>**

<sup>(a)</sup> INERIS, France

<sup>(b)</sup> Factory Mutual Research, USA

## ABSTRACT

*As a result of a fruitful collaboration initiated in 1994 between Factory Mutual Research and INERIS, round robin tests have been carried out in three Fire Propagation Apparatuses (FPAs), previously known as FMRC flammability apparatuses in the USA or 'Tewarson' calorimeters in Europe. The apparatuses (two operated by Factory Mutual Research and Approvals in Norwood in USA and the more recent one by INERIS in Verneuil-en-Halatte in France) are all meeting the requirements of the recently issued American standards ASTM E 2058 and NFPA 287. This poster briefly describes the development of the FPA, followed by the description of the round-robin testing programme carried out so far that includes ignition, combustion and propagation tests for seven commercially-important plastics. The materials have been characterised carefully from the thermo-chemistry point of view. Round robin results for the global flammability parameters such as CHF, TRP and FPI, as defined in the standards, are very encouraging, both in terms of repeatability of measurements in each laboratory and reproducibility of data from one lab to the other.*

## INTRODUCTION

Factory Mutual Research is historically the first user of the polyvalent Fire Propagation Apparatus in U.S.A. described in both recently issued standards ASTM E 2058<sup>1</sup> and NFPA 287<sup>2</sup> In Europe, INERIS commissioned in 1997<sup>3</sup> the first FPA meeting the mentioned standards, although early use of previous versions of equipment was there identified, in particular in France<sup>4,5,6</sup>.


Factory Mutual Research was responsible for the original design and has clearly shown the polyvalence of the apparatus for both material performance approvals and research purposes regarding flammability properties<sup>7,8,9</sup>. INERIS on the other end has mainly contributed thus far to the promotion of the equipment in learning about the fire behaviour of materials and chemicals in both well and under-ventilated conditions<sup>10,11,12</sup>.

Towards the end of year 2000, a new collaborative work was agreed between Factory Mutual Research and INERIS to study the reproducibility of data. We hereafter give the background of work, description of FPAs used in the study and materials selected for the comparisons, as well as preliminary results. The study is expected to be completed by the end of this year.


## FROM EARLY 'FMRC' FLAMMABILITY APPARATUS TO FIRE PROPAGATION APPARATUS (FPA) OF TODAY

Considerable efforts were made by the Factory Mutual Research to refine the design of the 50kW lab-scale flammability apparatus as it is referred to in early technical papers. So doing the evolution through 25 years of development have led to a very mature and polyvalent concept. The reader may appreciate the importance of the underlying technological evolution by comparing early drawings of the equipment provided by first users (see for instance references<sup>13,14</sup>) to upgraded version of the FPA that was issued in the mid 90's (see figure 1).


The efforts have continued for the last five years to promote the recognition and the use of the Fire Propagation Apparatus in a collaborative way for important purposes such as for testing materials (figure 2) for clean rooms<sup>15</sup> by Factory Mutual Research and Approvals or for the qualification of under-ventilated fires of chemicals<sup>12</sup> by INERIS (figure 3).



**Figure 1 : Sketch of the current version of the FPA, as finalised by FMR, Research division**



**Figure 2 : view of the FPA of FMR, Approvals division**



**Figure 3 : the INERIS FPA laboratory (Photograph : P. Robin)**

## ROUND ROBIN TESTS PROGRAMME

For the round robin testing, a first series of seven commercially available plastics were selected :

1. Polymethylmethacrylate (PMMA) (FPI > 20)
2. Polyoxymethylene (POM), Delrin® (FPI of the order of 14)
3. Polycarbonate (PC), (FPI in the range between 12 and 14)
4. Polysulfone (POS) (FPI ≈ 11)
5. Rigid Polyvinyl chloride (PVC) (FPI in the range between 7 and 8)
6. Polyetherimide (PEI)
7. Nylon (PA 6-6)

All 7 selected polymers are listed in table 1 with information on commercial designation of the materials and their suppliers. Table 2 lists the theoretical composition of each polymer.

Enough samples had been ordered in a single procedure in the form of sheets such that the tests could be performed in at least four apparatuses. Indeed, a fourth apparatus which is the prototype of the commercial version delivered by the UK company F.T.T. Ltd to Factory Mutual Approvals was also available. This latter apparatus was not used in the overall round-robin tests, as a separate evaluation process was in progress<sup>16</sup>. The samples (about 100 mm by 100 mm by 25 mm thick slabs for ignition and combustion tests, and 100 mm wide, 300 mm high and 25 mm thick slabs for propagation tests) were prepared at Factory Mutual Research by a single operator according to requirements of FM 4910 testing standard<sup>17</sup> and distributed to all operators involved. All samples were blackened using a *Thermalox 250* spray paint.

	Manufacturer /supplier	Commercial designation
Polymethylmethacrylate (PMMA)	Polycast technology (USA)	Poly 76 polycast acrylic sheet
Polycarbonate (PC)	Sheffield Plastics, Inc, Sheffield, MA (USA)	Hyzop GP polycarbonate sheet
Polyoxymethylene (POM)	A.L. Hyde Company (supplier) E.I. Dupont de Nemours & Co (Inc), Wilmington, DE, (USA)	Delrin® acetal resin
Polysulfone (POS)	Scientific Polymer Products (USA), Ontario, NY (USA)	Polysulfone resin 046-C
Rigid PVC	Vycom (Pa) USA	Polyvinyl chloride sheet
Polyetherimide (PEI)	DSM Engineering Plastic products Inc Reading, PA (USA)	Ultem product, natural (1000)
Nylon (PA 6-6)	A.L. Hyde Company (supplier) E.I. Dupont de Nemours & Co (Inc), Wilmington, DE, (USA)	Zytel® nylon resin

**Table 1 : technical identification of test materials**

The testing procedures described in ASTM E 2058 were followed by all laboratories involved in the study to perform consistently ignition, combustion and propagation tests.

polymers	mass % of overall sample weight					
	C%	H%	O%	N%	S%	Cl%
PMMA	60	8.0	32.025	0	0	0
PC	75.6	5.5	18.9	0	0	0
POM	40.0	6.7	53.3	0	0	0
POS	73.3	5.0	14.5	0	7.2	0
PVC	38.4	4.8	0	0	0	56.8
PEI	75.0	4.05	16.2	4.73	0	0
PA 66	63.7	9.73	14.2	12.4	0	0

**Table 2 : theoretical chemical composition of selected polymers (no additives)**

## RESULTS

### Detailed characterisation of the test samples

Table 3 summarises the results from chemical analysis performed by INERIS to accurately qualify the chemical nature of the plastics selected for the round-robin tests. A comparison with the theoretical composition in table 2 shows that all the polymers are relatively pure except PVC. Also POM contains some nitrogen compound as an impurity.

materials	mass % of overall sample weight					
	C%	H%	O%	N%	S%	Cl%
<b>PMMA</b>	60.1 ±0.1	8.56 ±0.04	32.14 ±0.25	< 0.1	< 0.04	< 0.02
<b>PC</b>	75.7 ±0.1	5.50 ±0.05	18.40 ±0.25	< 0.1	< 0.04	< 0.02
<b>POM</b>	41.4 ±0.1	6.91 ±0.09	51.40 ±0.25	0.15 ± 0.05	< 0.04	< 0.02
<b>POS</b>	72.9 ±0.1	4.82 ±0.04	14.39 ±0.25	< 0.1	8.2 ± 0.1	0.02 ±0.1
<b>PVC</b>	38.9 ±0.1	4.77 ±0.04	4.33 ±0.25	< 0.1	0.36 ± 0.02	49
<b>PEI</b>	73.83	4.07	17.98	4.89	< 0.02	< 0.02
<b>PA 66</b>	61.86	10.24	17.82	11.96	< 0.02	< 0.02

**Table 3 : Results of the elemental analysis of test samples performed by INERIS**

INERIS also measured the complete heats of combustion of all plastic samples selected for the round robin tests using an oxygen bomb calorimeter by INERIS following the French standard AFNOR NF M 03-005. Results are reported in table 4 that also includes predicted values as given by the *Boie's* and *Garvin's* correlations<sup>18</sup>. The comparison between predicted and measured values shows good agreement, except for rigid PVC where the measured value is somewhat higher than expected. The agreement for the heats of combustion is consistent with the true elemental analysis of the materials (table 3).

	Predicted values for pure polymers(a) <sup>18</sup>		Measured values on samples
	Boie's correlation	Garvin's correlation	
<b>PMMA</b>	25.14	25.57	24.76 ±0.03
<b>PC</b>	29.71	30.35	29.88 ±0.02
<b>POM</b>	14.48	14.88	15.72±0.02
<b>POS</b>	29.64	30.27	30.42±0.02
<b>PVC</b>	18.07	17.1	19.31±0.04
<b>PEI</b>	28.72	29.48	28.27 ±0.02
<b>PA 66</b>	30.84	31.36	29.17 ±0.03

(a) with use of the theoretical elemental composition of pure polymers for the calculations)

**Table 4 : Net heats of combustion (all values in MJ/kg)**

The data show that except for rigid PVC, the commercial products selected are very close in terms of chemical composition to the parent pure polymers. Rigid PVC sample contains some non identified oxygenated additive, that results in lower content of the chlorine element compared to pure PVC and thus in slightly more energetic product.


One may notice the presence of minor amount of nitrogen in the POM sample (confirmed during the combustion tests of POM samples though the detection of nitrogen oxides in the INERIS FPA (see figure 3), which is equipped with some additional on-line chemical analysis capabilities<sup>19</sup>). Some sulfur (in addition to oxygen) is also present in the PVC sample.

## Basic findings from preliminary comparisons of round robin tests

### Ignition tests

Time-to-ignition for sustained ignition is measured visually by a stop watch. Its measurement was found to be remarkably similar between various operators (rarely more than 1 second of difference between two operators monitoring a single test run in one lab), although recording of the time is not always easy.

From preliminary comparisons of data, a reasonable agreement was found between the raw data and data derived for the flammability parameters CHF (critical heat flux) and TRP (Thermal Response Parameter). A potential improvement of ignition test procedure was identified for further tightening the agreement. The improvement consisted of repeating each measurement at least three times for each heat flux applied during the test and do the relevant statistical treatment of the data. This would be essentially useful for difficult heavily charring materials or when "transient" ignition processes occur prior to sustainable ignition.



**Figure 4 : graphical determination of TRP (slope of the curves) in the case of PMMA**

### Propagation and combustion tests

Combustion tests were performed in normal air with samples exposed to 50 kW/m<sup>2</sup> to quantify yield of smoke. Fire propagation tests were performed in 40% oxygen concentration for 300 mm long vertical samples with bottom exposed to 50 kW/m<sup>2</sup> to quantify the heat release rate during upward fire propagation. The measured heat release rate was combined with the TRP value from ignition test to calculate the Fire Propagation Index (FPI). The value of FPI was multiplied by the smoke yield to determine the Smoke Development Index (SDI).

In the round robin testing, rate of heat release was in remarkably close agreement between the three labs. The agreement was excellent for non charring materials (both peak values of HRR and HRR profile versus time) and in good agreement for charring materials (at least peak values). In the latter case, the very complex charring process causes minor discrepancies in the detailed evolution of rate of heat release versus time, but not the peak value and the final ranking of the material, in terms of FPI.

## CONCLUSIONS AND PERSPECTIVES

A series of round robin tests on a selection of seven plastics have been successfully carried out by three laboratories operating a Fire Propagation Apparatus meeting the technical requirements of the recently issued ASTM E 2058 and NFPA 287 standards. A detailed characterisation of the materials has been performed and recorded.

Basic observations confirm satisfactory repeatability of measurements in each lab and the analysis of the results for the appraisal of reproducibility of data from one lab to the other looks very encouraging. The reproducibility of the ignition, propagation and combustion test procedures is

reasonable, in particular in terms of the time to ignition measurements, and calculated rate of heat release for all samples. However, improvements of test protocols such as using cross wires for the sample conditioning whenever the material to be tested is charring or not and repeating at least three times the time to ignition measurement protocol (to eliminate isolated aberrant data plot) for each heat flux increment in the series of ignition tests have been identified as immediate simple things having clear positive impacts.

It is intended to analyse the data further in terms of reproducibility (according for instance to standard ISO 5755) and related calculated flammability parameters such as CHF (critical heat flux), TRP (thermal response parameter), FPI (fire propagation index) or SDI values (smoke development index). Further testing on samples of 2 foam plastics (PUR and PIR) and fire retarded polyester is also planned. Once the work is completed, the results will be published in the open literature.

## LITERATURE

- <sup>1</sup> ASTM, Standard test Methods for Measurement of Synthetic Polymer Material Flammability Using a Fire Propagation Apparatus (FPA), ASTM E 2058 – (2000 Edition)
- <sup>2</sup> NFPA 287 Standard Test methods for Measurement of Flammability of Materials in Cleanrooms Using a Fire Propagation Apparatus (FPA) 2001 Edition
- <sup>3</sup> M. Nominé & G. Marlair, "Thermal and Toxic Effects of Fire : Investigation of the Laboratory Calorimeter, INERIS Scientific Report, 1997 edition (In French)
- <sup>4</sup> H. Ledoux, "Development and Use of the Tewarson Lab-scale Apparatus at LCIE", Technical Workshop on FPA Users, INERIS, Verneuil-en-Halatte, Nov 1997
- <sup>5</sup> G. Marlair, C. Costa, B. Gautier, H. Ledoux & S. Brohez, "On-going Experimental Fire Research and Testing in France using Tests Rigs Derived from the 'Tewarson' Apparatus", 6<sup>th</sup> International Symposium on Fire Safety Science, Poitiers July 1999 (poster session)
- <sup>6</sup> J. F. Chapman, B. Cope, G. Marlair and F.H. Prager, "Fire behaviour of MDI and TDI", part 5.5 (Supporting sciences) of 'MDI and TDI : Safety, Health and the Environment', John Wiley and Son (to be published)
- <sup>7</sup> A. Tewarson, "The SFPE Handbook of Fire Protection Engineering", 2<sup>nd</sup> edition, The NFPA Press, Quincy, Ma, 1985, 3-53-3-124
- <sup>8</sup> A. Tewarson, F.H. Jiang and T. Morikawa, "Ventilation Controlled Combustion of Polymers", Combustion and Flame, 95:151-169 (1993)
- <sup>9</sup> Factory Mutual, Approval Standard Class 1 Conveyor Belting, Class # 4948, August 1995
- <sup>10</sup> K. Adam, "Dioxins emissions from combustion of electric cables", INERIS annual scientific report, 1999 Edition, p 26-29
- <sup>11</sup> G. Marlair et al, "Experimental Evaluation of the Fire Hazard of Organophosphorous Insecticides By Use of Various Test Methods", Industrial Fires III European Meeting, Ris, Denmark, 17-18 Nov 1996, Proceedings EUR 17477, pp 93-110
- <sup>12</sup> G. Marlair, J-P. Bertrand & S. Brohez, "The Use of the ASTM E 2058 Fire Propagation Apparatus for The Evaluation of Under-ventilated Fires", Fires and Materials 2001, Jan 22-24, 2001, San-Francisco (USA), pp 301-313
- <sup>13</sup> A. Tewarson, "Heat Release rates from Burning Plastics", J. Fire & Flammability, Vol 8 (Jan 1977), pp 115-130)
- <sup>14</sup> R.V. Petrella, "The Mass Burning Rate of Polymers, Wood and Organic Liquids", Journal of Fire & Flammability, Vol 11 (Jan 1980), pp 3-21
- <sup>15</sup> A. Tewarson, M.M. Khan, P.K. Wu and R.G. Bill Jr, "Flammability Evaluation of Clean Room Polymeric Materials for the Semi-Conductor Industry", Fire and Materials, 25, 31-42 (2001)
- <sup>16</sup> M.M. Khan and S. Gregory, "The Performance of the Commercial Version of the Fire Propagation Apparatus", Fires and Materials 2001, Jan 22-24, 2001, San-Francisco (USA), pp 379-387
- <sup>17</sup> Factory Mutual, Test Standard FMRC Clean Room Materials Flammability Test Protocol, Class # 4910, September 1997
- <sup>18</sup> G. Marlair, C. Cwiklinski & A. Tewarson, "An Analysis of practical Methods for Estimating Heats of Combustion in Fire Safety Studies", Interflam '99 Fire Science and Engineering Conference, Edinburgh 29 June-1<sup>st</sup> July 1999, Conf. Proc. pp 201-212
- <sup>19</sup> G. Marlair, "Industrial Fires in Enclosures", INERIS annual scientific report, 2000 Edition